

## FLOOR DRAIN WITH DRAINAGE TYPE TRAP PRIMER DETAIL

## NOTES:

- 1. DETAIL SHALL ONLY BE USED TO SERVE SINGLE TRAP FOR BATHROOM APPLICATION PER CODE.
- 2. ALL INACCESSIBLE PIPING (SUCH AS EMBEDDED IN CONCRETE) SHALL BE SOFT COPPER WITH MECHANICAL CONNECTIONS NOT SOLDERED, ALL OTHER PIPING MUST BE HARD COPPER PER SPECIFICATIONS.

 ${\tt CS\_STD\_MEC\_221319\_DRAIN\_TYPE\_TRAP\_PRIMER.dwg}$ 

MICHIGAN STATE UNIVERSITY

Infrastructure Planning and Facilities FLOOR DRAIN WITH DRAINAGE TYPE TRAP PRIMER DETAIL DATE DETAIL NO.
2007 221319-01

DRAWN REVISION

EAS

221319-01 REVISION 7/11/16 RLANDRUM OF ONE

SHEET