

FLOOR DRAIN WITH WATER SUPPLY FED TRAP PRIMER DETAIL NO SCALE

NOTES:

- 1. TRAP PRIMER SHALL ONLY BE USED TO SERVE SINGLE TRAP.
- IN FINISHED AREA, ROUTE PIPING WITHIN WALL AND LOCATE TRAP PRIMER IN A RECESSED BOX. BOX SHALL BE FULL SIZE TO SERVICE VALVE AND TRAP PRIMER ASSEMBLY. MINIMUM 12X12 FOR ONE ASSEMBLY.
- 3. ALL INACCESSIBLE PIPING, SUCH AS BURIED IN CONCRETE, SHALL BE SOFT COPPER WITH MECHANICAL CONNECTIONS. ALL OTHER PIPING SHALL BE HARD COPPER.

 ${\it CS_STD_MEC_221319_WTR_SUPPLY_TRAP_PRIMER.dwg}$

MICHIGAN STATE UNIVERSITY

Infrastructure
Planning and Facilities

FLOOR DRAIN WITH WATER SUPPLY FED TRAP PRIMER DETAIL DATE DETAIL NO.
2007 221319-02

DRAWN REVISION

DRAWN REVISION
EAS 7/11/16
RLANDRUM

