



STEAM REHEAT COIL PIPING DIAGRAM

NO SCALE

NOTES:

1. FOR PIPE 2" AND SMALLER, REDUCE FULL SIZE DIRT LEG TO 1" BY REDUCING COUPLING THEN A SCREWED RISING STEM VALVE, NIPPLE AND A SCREWED CAP. FOR PIPE 2 1/2" AND LARGER, USE WELDED CAP AND WELD A 1" WELD-O-LET IN CAP AND USE A SCREWED VALVE, NIPPLE AND A SCREWED CAP FOR A BLEEDER.
2. USE UNIONS FOR PIPING LESS THAN 1" AND COMPANION FLANGES FOR PIPING 1" AND ABOVE.
3. INSTALL COIL WITH ENOUGH VERTICAL CLEARANCE FOR CONDENSATE LINE, DIRT LEG AND CAP REMOVAL.

CS_STD_MEC_233600_STEAM_REHEAT.dwg