



FULL LINE UP TO 2", 2 1/2" AND LARGER TO USE WELDED CAP WITH 2" THREAD-O-LET FOR BLOWDOWN

NOTE: FOR SYSTEMS WITH MULTIPLE TRAPS, INSTALL SHUT-OFF VALVE UPSTREAM OF STRAINER ON EACH BRANCH.

HEAT EXCHANGER TRAP ASSEMBLY DETAIL  
NO SCALE

CS\_STD\_MEC\_235700\_HEAT\_EXCH\_TRAP\_ASSEMBLY.dwg

<b>MICHIGAN STATE UNIVERSITY</b>   Infrastructure Planning and Facilities	HEAT EXCHANGER TRAP ASSEMBLY PIPING DIAGRAM		DATE	DETAIL NO.	SHEET  OF ONE
			10/10/7	235700-01	
			DRAWN	REVISION	
			EAS	7/12/16	
				RLANDRUM	