



HWH CONVECTOR OR CABINET UNIT HEATER
PIPING DIAGRAM WITH TWO-WAY CONTROL VALVE
 NO SCALE

NOTES:

1. USE UNIONS FOR PIPING LESS THAN 1" AND COMPANION FLANGES FOR PIPING 1" AND ABOVE.
2. PROVIDE ACCESS AS REQUIRED.
3. PROVIDE MANUAL AIR VENT WITH ISOLATION VALVE IF BRANCH CONNECTION IS MADE ABOVE HORIZONTAL OR IF BRANCH PIPING MUST DROP DOWN AT ANY POINT ALONG HORIZONTAL.

CS_STD_MEC_238233_HWH_CONV_CUH_2_WAY.dwg