



HWH FIN TUBE RADIATION PIPING DIAGRAM
NO SCALE

NOTES:

1. USE UNIONS FOR PIPING LESS THAN 1" AND COMPANION FLANGES FOR PIPING 1" AND ABOVE.
2. PROVIDE ACCESS AS REQUIRED.
3. IF THE CEILING IS NOT ACCESSIBLE, LOCATE CONTROL VALVE AND ASSOCIATED DEVICES IN THE FINNED TUBE RADIATION COVER.
4. PROVIDE MANUAL AIR VENT WITH ISOLATION VALVE IF BRANCH CONNECTION IS MADE ABOVE HORIZONTAL, OR IF BRANCH PIPING MUST DROP DOWN AT ANY POINT ALONG HORIZONTAL RUN.

CS_STD_MEC_238233_HWH_FINTUBE_RAD.dwg

