

## SECTION 262813 – FUSES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:

- 1. This Section specifies the fuses for buildings and structures.
- 2. Provide all labor, materials, and equipment as necessary to complete all work as indicated on the drawings, and as specified herein for a complete operating system.

- B. Related Sections:

- 1. Applicable sections of Division 26 - Electrical

#### 1.3 SUBMITTALS

- A. Shop Drawings

- 1. Low-voltage fuses.

### PART 2 - PRODUCTS

#### 2.1 FUSES

- A. Fuses where required and/or specified for electrical equipment shall be Bussmann Fusetrons or equal by Littelfuse.
- B. Where fused disconnect switches are used protect for wire protection fuses shall be sized to protect the wire and be furnished for the disconnect switches.
- C. Fuses sized for motor protection shall be furnished for all combination starters. (Not greater than 125% of motor nameplate rating.)
- D. Fuses sized as shown on drawings shall be installed in all non-motor starter switches of motor control centers.

PART 3 - EXECUTION

Not used.

END OF SECTION 262813