

NOTES:


1. FOR USE ONLY WHEN A THREE-WAY CONNECTION NEEDS TO BE MADE.
2. THE 3" SCH 40 CONDUITS ARE NOT REQUIRED WHEN THE PULLBOX IS IN A GREEN SPACE.
3. WIRE FROM BASE TO LUMINAIRE SHALL BE 3#10 AWG USE STRANDED COPPER, 600V INSULATION.
4. WIRING FROM BASE TO PULL BOX SHALL BE #4 AWG 3 CONDUCTOR STREETLIGHT CABLE.
5. REFER TO BASE DETAIL 265600-02 FOR ANCHOR BOLT INFORMATION, GROUND ROD AND BASE INSTALLATION.
6. STREET LIGHT PULL BOX SHALL BE HUBBELL CDR CATALOG NO. B1211818A BOX AND C1211802A COVER, WITH PENTA-SOCKET BOLTS AND "STREET LIGHT" LOGO.

NOTE 2

3" SCH 40 PVC CONDUIT ELBOW WITH ENDBELL, ONE EACH ALONG BOTH DIRECTIONS OF ROADWAY WHERE HARD SURFACES EXIST.

2" SCH 40 PVC WITH ENDBELL.

EXISTING SUBGRADE



STREET LIGHT WITH PULL BOX
NOT TO SCALE

SEE SPECIFICATION SECTION 265600 EXTERIOR LIGHTING

DATE 6/16/09	DETAIL NO. 265600-01	SHEET 1 OF ONE
DRAWN	REVISION 11/29/18	