



NOTES:

1. DO NOT CROSS CABLES IN TRENCH.
2. FILL FIRST 6" WITH SAND. REMOVED EARTH MAY ONLY BE USED IN THE FIRST 6" IF IT IS HAND SHOVELED, FREE OF STONES AND OTHER DEBRIS.
3. COMPACT TRENCH AFTER CABLE INSTALLATION.

X
 X-X

 TRENCH DETAIL
 NOT TO SCALE

SEE SPECIFICATION SECTION
265600 EXTERIOR LIGHTING

MICHIGAN STATE UNIVERSITY Infrastructure Planning and Facilities	CABLE BURIAL TRENCH TYPICAL DETAIL	DATE 6/16/09	DETAIL NO. 265600-06	SHEET 1
		DRAWN	REVISION 11/29/18	OF ONE