

# Proposed – Southwest Regional Chilled Water Plant, CP23037

01/06/2024

Director of Planning, Design and  
Construction (PDC):  
John LeFevre, P.E.  
[lefevr20@msu.edu](mailto:lefevr20@msu.edu)  
PH#: 517-256-6447


Project Manager:  
M. Scott Gardner, P.E.  
[gardne21@msu.edu](mailto:gardne21@msu.edu)  
PH#: 517-432-0782

# Opportunity:

The proposed West Regional Chilled Water Plant (with future expansion) will provide cooling to Engineering Digital Imaging Center, existing facilities with failing chillers (Anthony, Food Science, Erickson, Wells, & International Center), and provide future cooling capacity for anticipated Building Opportunities in the Land Use Master Plan Framework.

Regional plants provide a cost-effective platform to deliver energy savings and sustainability technologies across a large geographic regions.

# West Regional Chilled Water Plant - Phases



# Regional Plant Advantages:

- **Greater opportunity for significant energy savings and meeting sustainability goals.**
  - Can leverage Thermal Storage to reduce peak demands.
  - “Free” Winter Chilled Water Source - The proposed regional chilled water plant would provide winter chilled water (process cooling) service via a waterside economizer cycle using the plant’s cooling towers and plate heat exchangers.
  - Provides a platform for other energy technologies to be deployed.
  - Regional Plants play a major role in achieving sustainability goals.
  - Regional Plant approach will play a key role in balancing the electric and thermal loads at the Power Plant allowing the plant to operate at optimal performance (reducing our carbon footprint).
- **Diversity among connected loads and strategic load balancing thereby reducing the tonnage of chiller capacity needed.**
  - Allows chillers to be fully loaded for optimal energy efficiency while providing N+1 redundancy versus running equipment partially loaded conditions.
- **Allows operations and maintenance to be performed without disruption of service.**
  - When multiple chillers are in series, one can be removed from service for repair or replacement without affecting the connected load.
  - Maintenance can be completed centrally, away from teaching and research functions to avoid disruption. I.E., cooling tower plume, chemical handling, vibration, truck deliveries, noise, etc.
  - Regional Plants require less equipment (chillers, cooling towers, pumps, and electrical distribution equipment) to provide the same level of cooling capacity and redundancy.
- **Capital costs are more economical than numerous individual localized chillers.**
  - Regional Plant require less equipment (chiller and cooling tower capacity, pumps, electrical equipment, etc..) while maintaining N+1 reliability.
  - Regional Plants require less Utility Infrastructure than de-centralized (individual Buildings/Additions) system approach.
  - Reduces the required mechanical and electrical room space in future buildings and additions (approximately 43,000 SF for this region).

## Advantages related to Technologies:

- The steam/electric option for the regional chilled water plant provides the following additional advantages:
  - STEAM-SOURCED COOLING - This option provides the most cost effective and practical way to provide steam-sourced cooling to the campus if the long term campus utility plan includes the continued use of centrally distributed steam.
  - LESS ELECTRICAL DISTRIBUTION – Greatly reduced campus electrical distribution requirements than with the all-electric regional chilled water plant option or the decentralized option, freeing available primary circuits for campus building growth. Makes use of existing campus steam distribution system to power 72% of the regional plant's chiller capacity while also helping to balance the steam versus electric load on the central power plant.
  - REDUCED ELECTRIC DEMAND - Reduces cooling-related campus electrical demand by 10 MW as compared to the all-electric regional chilled water plant option, and by 11 MW as compared to the decentralized option.
  - ELECTRIC LOAD SHEDDING CAPABILITY - A standby 2,800 ton chiller is included with the initial phase and onward, which could be energized in place of one of the equal capacity electric chillers in the plant to quickly reduce campus electric demand by 1.7 MW without reducing cooling service.
  - STEAM AND ELECTRIC LOAD BALANCE - Allows switching between steam and electric chillers, a potential benefit to the efficiency of the campus power plant and its steam and electric distribution systems.
  - EFFICIENT STEAM USE - The proposed steam turbine driven chillers reduce steam use by 50% as compared to providing an equivalent amount of cooling from steam absorption chillers.
  
- The all-electric option for the regional chilled water plant provides the following additional advantages:
  - AVOIDS STEAM-SOURCED COOLING - This option avoids steam-sourced cooling if the long term campus utility plan were to discontinue the use of centrally distributed steam.
  - REDUCED ELECTRIC DEMAND - Reduces cooling-related campus electrical demand by 1 MW as




# MSU West Regional Chilled Water Plant Study


## Cumulative Project Cost by Phase (2025 Dollars)

	Building Net GSF Served	Regional Plant					Decentralized Chillers at Buildings		
		Total Installed Cooling (N+1)	Cooling Tonnage (N)	Steam/Electric Chillers at West Regional Chilled Water Plant	Steam (lbs/hr)	Electric (kW)	Decentralized Chillers at Buildings	Steam (lbs/hr)	Electric (kW)
Phase 1-2-3	2,730,487	11,800	9,000	\$ 85,557,838	(56,000)	3,818	\$ 94,059,106	(114,600)	6,850
Phase 4	4,180,687	14,600	11,800	\$ 98,958,926	(56,600)	5,914	\$ 145,697,004	(114,600)	12,650
Phase 5	7,907,683	23,400	20,600	\$ 173,599,862	60,400	7,884	\$ 262,977,615	(114,600)	19,250


Note: The decentralized approach requires 3 new circuit pairs from the Power Plant (including a dedicated circuit pair to EDI Center). Additionally, the decentralized option have major second order implications to the Power Plant and Electrical Distribution System.



## West Regional Chilled Water Options Study 23 Year Life Cycle Cost Summary



## West Regional Chilled Water Options Study Carbon Footprint Comparison







# Summary:

- Investment for a regional plant is \$8.5 M less than anticipated decentralized investment for Facilities outlined in Phase 1-2-3.
- Investment offset by approx. \$18 M from stand alone project chillers that are slated to be deployed currently (EDI Center, Packaging and Student Rec.)
- Retires approximately \$45.6M (Anthony/Food Sci. @\$20.3M, International Center @\$12.8M, and Wells Hall @\$12.5M) of Capital Renewal for chillers which need to be replaced within the next 5 years.
- The 23 Year Life Cycle Cost Analysis for this regional plant vs decentralized cooling will save approximately the following:
  - Phase 1-2-3: \$ 5.4 M
  - Phase 4: \$45.3 M
  - Phase 5: \$78.1 M
- Central Chilled Water Plants require approximately 35% less equipment than a decentralized plants and allow the equipment to be staged for optimum performance, thus significantly reducing the amount of energy required and minimizing the embodied carbon footprint for primary equipment.
- The proposed Regional Chilled Water Plant creates a platform to save significant amounts of energy, allows other energy technology to be deployed regionally (Thermal Storage, etc.) to meet sustainability goals, reduces overall cost of operations and maintenance.
- Regional Plant's **significantly** reduce the amount of Utility Infrastructure Distribution Systems (electric, steam, water, etc.) required versus decentralized thermal (cooling and/or heating) approaches.
- The proposed regional plant is being coordinated with Major Capital Projects, and the Campus Land Use and Utility Infrastructure Plans.

# Site Planimetric View




# Phase 1-2: Looking from the Southeast



# Proposed Building Floor Plan

Phase 5 (Future)

Phase 1-2-3-4




FIRST FLOOR PLAN - STEAM & ELECTRIC BLEND OPTION  
1/8" = 1'-0"



# Proposed Building Roof Plan

Phase 5 (Future)


Phase 1-2-3-4



ROOF PLAN  
1/8" = 1'-0"




# Proposed Building Cross Section




SECTION

# Site Planametric View



## Phase 1-2: Looking from the Southwest





# Phase 1-2: Looking from the Southwest




# Phase 1-2: North Elevation






# Phase 1-3: Looking from the Southeast




# Phase 1-3: Looking from the Southwest






# Phase 1-3: North Elevation





XXX



# Questions ?

Project Manager:

M. Scott Gardner, P.E.

[gardne21@msu.edu](mailto:gardne21@msu.edu)

PH#: 517-432-0782

Information Technology Asst Director:


Sharon Bennett

[bennet50@msu.edu](mailto:bennet50@msu.edu)

PH#: 517-884-3067



# Detailed Schematic Site Map



# Phase 1

PHASE 1			
<b>Buildings Served</b>			
<u>Building</u>	<u>Sq Ft</u>	<u>Tons</u>	<u>Present Cooling Source</u>
C14 - EDIC	262,500	1,500	Not yet constructed
C20 - PACKAGING ADDITION	64,400	215	Not yet constructed
ENGINEERING BUILDING	421,497	1,531	Engineering CHW Loop
COMM. ARTS AND SCIENCES	262,442	612	Engineering CHW Loop
ANTHONY HALL	319,754	1,347	Engineering CHW Loop
PACKAGING	56,162	206	Engineering CHW Loop
FOOD SCIENCE	120,101	608	Engineering CHW Loop
NATURAL RESOURCES	149,972	395	Engineering CHW Loop
C-03 STUDENT RECREATION AND WELLNESS CENTER	305,000	987	Not yet constructed
Total Connected Loop Load	1,961,828	7,401	
Diversified Loop Load	80%	5,921	
<b>Existing Loop Chillers and Cooling Towers to Remain Operational</b>			
<u>Location</u>	<u>Quantity</u>	<u>Tons Capacity</u>	
Engineering - 1200 ton electric centrifugal	2	2400	
Anthony Hall - 955 ton steam absorption	2	1910	
Food Science - 620 ton steam absorption	2	1240	
<b>Existing Loop Chillers and Cooling Towers to be Removed</b>			
<u>Location</u>	<u>Quantity</u>	<u>Tons Capacity</u>	
None			
<b>New Chiller Plant Building Size (approx.)</b>		160'x125'	
<b>New Chillers</b>		<u>Quantity</u>	<u>Tons Capacity</u>
1000 ton electric centrifugal		1	1000
2800 ton steam turbine centrifugal		1	2800
2800 ton electric centrifugal		0	0
Total installed chiller capacity in WRCW plant		2	3800
Total Installed chiller capacity on WRCWP loop		8	9350
N-1 chiller capacity on WRCWP loop		7	6550
Chiller capacity on WRCWP loop if all absorption chillers failed but all centrifugal chillers operational		4	6200
Installed Chiller Capacity on WRCWP loop as % Diversified Load		158%	
N-1 Chiller Capacity on WRCWP loop as % Diversified Load		111%	
Chiller capacity on WRCWP loop as % Diversified Load if all absorption chillers failed but all centrifugal chillers operational		105%	
Site Steam Piping	New 20" steam and 10" condensate services to plant through crawl tunnel. Connect steam service to both existing 24" steam service mains at Vault #210		
Net added campus summer steam load for cooling, cumulative through phase (lbs/hr)	Steam turbine	29,000	
	Absorption	no change	
	Total	29,000	
Site Chilled Water Piping	Extend site chilled water piping from WRCWP to Engineering Loop, to EDIC, to Student Recreation and Wellness Center and to northwest side of the intersection of Red Cedar Road and North Shaw Lane.		
Site Electrical	1. Need a new electrical duct bank from ELE 1848 (Trowbridge Road, north of Railroad Crossing) to the south side of the WRCWP. 2. Requires a new 15KV circuit pair (H-11 & H-31) from T.B. Simon Power Plant to the new WRCWP building. MSU Cost: \$1,472,000		
Net added campus summer electrical load for cooling, cumulative through phase (kW)	1,230		

# Phase 2

PHASE 2			
<b>Additional Buildings Served</b>			
<u>Building</u>	<u>Sq Ft</u>	<u>Tons</u>	<u>Present Cooling Source</u>
C20 - PACKAGING ADDITION	64,400	215	Not yet constructed
Additional Connected Load	64,400	215	
Total Connected Loop Load	2,026,228	7,616	
Diversified Loop Load	80%	6,093	
<b>Existing Loop Chillers and Cooling Towers to Remain Operational</b>			
<u>Location</u>	<u>Quantity</u>	<u>Tons Capacity</u>	
Engineering - 1200 ton electric centrifugal	2	2400	
WRCWP - 1000 ton electric centrifugal	1	1000	
WRCWP - 2800 ton steam turbine centrifugal	1	2800	
<b>Existing Loop Chillers and Cooling Towers to be Removed</b>			
<u>Location</u>	<u>Quantity</u>	<u>Tons Capacity</u>	
Anthony Hall - 955 ton steam absorption	2	1910	
Food Science - 620 ton steam absorption	2	1240	
<b>New Chiller Plant Building Size (approx.)</b>	No Change		
<b>New Chillers</b>	<u>Quantity</u>	<u>Tons Capacity</u>	
1000 ton electric centrifugal	0	0	
2800 ton steam turbine centrifugal	0	0	
2800 ton electric centrifugal	1	2800	
Total installed chiller capacity in WRCW plant	3	6600	
Total Installed chiller capacity on WRCWP loop	5	9000	
N-1 chiller capacity on WRCWP loop	4	6200	
Installed Chiller Capacity on WRCWP loop as % Diversified Load		148%	
N-1 Chiller Capacity on WRCWP loop as % Diversified Load		102%	
Site Steam Piping	No Change		
Net added campus summer steam load for cooling, cumulative through phase (lbs/hr)	Steam turbine		29,000
	Absorption		-58,905
	Total		-29,905
Site Chilled Water Piping	No Change		
Site Electrical	No Change		
Net added campus summer electrical load for cooling, cumulative through phase (kW)			3,326



# Phase 3

PHASE 3			
<b>Additional Buildings Served</b>			
<u>Building</u>	<u>Sq Ft</u>	<u>Tons</u>	<u>Present Cooling Source</u>
WELLS HALL	315,886	980	International Center/Wells Hall CHW Loop
ERICKSON HALL	219,249	730	International Center/Wells Hall CHW Loop
INTERNATIONAL CENTER	133,524	564	International Center/Wells Hall CHW Loop
Additional Connected Load	668,659	2,274	
Total Connected Loop Load	2,694,887	9,890	
Diversified Loop Load	80%	7,912	
<b>Existing Loop Chillers and Cooling Towers to Remain Operational</b>			
<u>Location</u>	<u>Quantity</u>	<u>Tons Capacity</u>	
Engineering - 1200 ton electric centrifugal	2	2400	
WRCWP - 1000 ton electric centrifugal	1	1000	
WRCWP - 2800 ton steam turbine centrifugal	1	2800	
WRCWP - 2800 ton electric centrifugal	1	2800	
<b>Existing Loop Chillers and Cooling Towers to be Removed</b>			
<u>Location</u>	<u>Quantity</u>	<u>Tons Capacity</u>	
Wells Hall - 490 ton steam absorption	2	980	
International Center - 800 ton steam absorption	2	1600	
<b>New Chiller Plant Building Size (approx.)</b>		No Change	
<b>New Chillers</b>		<u>Quantity</u>	<u>Tons Capacity</u>
1000 ton electric centrifugal		0	0
2800 ton steam turbine centrifugal		1	2800
2800 ton electric centrifugal		0	0
Total installed chiller capacity in WRCWP		3	9400
Total Installed chiller capacity on WRCWP loop		5	11800
N-1 chiller capacity on WRCWP loop		4	9000
Installed Chiller Capacity on WRCWP loop as % Diversified Load		158%	
N-1 Chiller Capacity on WRCWP loop as % Diversified Load		114%	
Site Steam Piping		No Change	
Net added campus summer steam load for cooling, cumulative through phase (lbs/hr)		Steam turbine	58,000
		Absorption	-107,151
		Total	-49,151
Site Chilled Water Piping		Extend site chilled water piping from northwest side of the intersection of Red Cedar Road and North Shaw Lane and connect to existing Wells Hall/International Center loop piping	
Site Electrical		No Change	
Net added campus summer electrical load for cooling, cumulative through phase (kW)		3,818	

# Phase 4

PHASE 2			
Additional Buildings Served			
<u>Building</u>	<u>Sq Ft</u>	<u>Tons</u>	<u>Present Cooling Source</u>
C-01	57,600	160	Not yet constructed
C-02	122,400	510	Not yet constructed
C-04 Remainder of master plan 218,000 gsf	118,300	328	Not yet constructed
C-05	324,000	900	Not yet constructed
C-08	175,200	584	Not yet constructed
C-09	160,000	533	Not yet constructed
C-10	160,000	533	Not yet constructed
C-15	259,500	865	Not yet constructed
C-16	73,200	244	Not yet constructed
Additional Connected Load (Tons)	1,450,200	4658	
Total Connected Loop Load (Tons)		14611	
Diversified Loop Load (Tons)	80%	11689	
	<b>Steam/Electric Chillers in Regional Chilled Water Plant</b>	<b>Decentralized</b>	
Chiller Plant Building Size (approx.)	No change		None
<u>New Chillers</u>	<u>Quantity</u>	<u>Tons Capacity</u>	
2800 ton steam turbine centrifugal		0	
2800 ton electric centrifugal	1	2800	<u>Chillers at buildings (based on average capacities):</u> (3) 244 ton electric air cooled chillers, and associated incremental 480V substation capacities
Total installed chiller capacity in plant	5	12200	
Total Installed chiller capacity on loop	7	14600	
N-1 chiller capacity on loop	6	11800	
Installed Chiller Capacity as % Diversified Load		125%	
N-1 Chiller Capacity as % Diversified Load		101%	(12) 523 ton electric centrifugal chillers, with cooling towers, condenser water pumps, dedicated water softener, a total of 20,000 sf of associated mechanical room floor space and associated incremental 480V substation capacities.
			5,800 kW total added electrical load for cooling equipment at new buildings
Site Steam Piping	No change		None
Net added campus summer steam load for cooling, cumulative through phase (lbs/hr)	Steam turbine chillers	59,000	Steam turbine chillers
	<u>Absorption chillers</u>	-114,600	Absorption chillers
	Total	-55,600	Total
			-114,600
Site Chilled Water Piping	Extend site chilled water piping mains from near International Center to master plan C-10 building site (existing Parking Lot #40)		None
Electrical	No change		No change
Net added campus summer electrical load for cooling, cumulative through phase (kW)		5,914	12,650



# Phase 5

PHASE 3			
Additional Buildings Served			
<u>Building</u>	<u>Sq Ft</u>	<u>Tons</u>	<u>Present Cooling Source</u>
JENISON FIELDHOUSE	203,109	677	Stand-alone Building System
DEMONSTRATION HALL	96,208	321	Stand-alone Building System
SPARTAN STADIUM	422,218	900	Stand-alone Building System
MUNN ICE ARENA	155,901	528	Stand-alone Building System
STEM	192,208	580	Stand-alone Building System
BRESLIN STUDENT EVENTS CENTER (includes HOH ad	336,185	1200	Stand-alone Building System
DUFFY DAUGHERTY FOOTBALL - S.A.A.C. - excludes ir	138,156	584	Stand-alone Building System
PUBLIC SAFETY	36,941	123	Stand-alone Building System
CASE HALL - Center Section Only	76,505	400	Stand-alone Building System
WILSON HALL - Center Section Only	72,130	262	Stand-alone Building System
WONDERS HALL - Center Section Only	82,735	301	Stand-alone Building System
HOLDEN HALL - Center Section Only	114,450	416	Stand-alone Building System
C-13	304,950	847	Not yet constructed
C-17	247,600	825	Not yet constructed
C-18A	314,500	953	Not yet constructed
C-18B	190,400	635	Not yet constructed
C-21	78,000	260	Not yet constructed
C-22	664,800	1385	Not yet constructed
Existing buildings	1,926,746		
Future new buildings per master plan	1,800,250		
Additional Connected Load (Tons)		11197	
Total Connected Loop Load (Tons)		25808	
Diversified Loop Load (Tons)	80%	20647	
Existing Loop Chillers and Cooling Towers to be Removed			
<u>Location</u>	<u>Quantity</u>	<u>Tons Capacity</u>	
Engineering - 1200 ton electric centrifugal	2	2400	
	Steam/Electric Chillers in Regional Chilled Water Plant		Decentralized
Chiller Plant Building Size (approx.)	120'x125' addition		None
<u>New Chillers</u>	<u>Quantity</u>	<u>Tons Capacity</u>	<u>Engineering:</u> Replace existing (2) 1200 ton electric centrifugal chillers, cooling towers, condenser water pumps
2800 ton steam turbine centrifugal	4	11200	
2800 ton electric centrifugal	0	0	
Total installed chiller capacity in plant	9	23400	<u>Chillers at buildings (based on average capacities):</u>
Total installed chiller capacity on loop	9	23400	(16) 298 ton electric air cooled chillers and associated
N-1 chiller capacity on loop	8	20600	incremental 480V substation capacities
Installed Chiller Capacity as % Diversified Load		113%	(14) 734 ton electric centrifugal chillers, with cooling towers,
N-1 Chiller Capacity as % Diversified Load		100%	condenser water pumps, dedicated water softener, a total of
			23,000 sf of associated mechanical room floor space
			associated incremental 480V substation capacities and .
			6,600 kW total added electrical load for cooling equipment at
			new buildings (assumes no net change in electrical load at
			existing buildings)
Site Steam Piping	No change		No change
Net added campus summer steam load for cooling, cumulative through phase (lbs/hr)	Steam turbine chillers	176,000	Steam turbine chillers
	<u>Absorption chillers</u>	<u>-114,600</u>	<u>Absorption chillers</u>
	Total	61,400	Total
Site Chilled Water Piping	Extend site chilled water piping mains to complete the loop along Wilson and Birch roads, from the new chilled water plant to the Student Recreation and Wellness Center		None
Electrical	Additional (second) 2.5MVA double ended substation in WRCWP		To support the decentralized chiller load in future new buildings, an additional new 15KV circuit pair would be required from T.B. Simon Power Plant to near Shaw Lane and Harrison Road. MSU Cost: \$2,689,000
Net added campus summer electrical load for cooling, cumulative through phase (kW)		7,884	19,250