

ADDENDUM
PAGE 1 OF 1

| | |
|-------------------------|---|
| OWNER: | Michigan State University 113 Student Services East Lansing, MI 48824 |
| ARCHITECT: | Fishbeck 39500 MacKenzie Drive, Suite 100 Novi, MI 48377 |
| DRAWING REVISION NO.: | A1 |
| ISSUED HEREWITH: | |
| SPECIFICATION SECTIONS: | None |
| SHEETS: | None |
| BIDS DUE: | March 22, 2024 |

This Addendum is issued to all Bid Set Holders, is a part of the Contract Documents, and modifies the previously issued Bidding Documents. Acknowledge receipt of this Addendum in the space provided on the Bid form; failure to do so may result in rejection of the Bid.

ITEM NO. 1:

Questions Received from Potential Bidders:

- A. **Question:** Sheet A-008 door schedule – note 1 indicates existing door to remain. Is the frame to remain or be replaced with new frame?

Response: The existing door frames will remain.

- B. **Question:** Sheet A-003 keynote 6 indicates for 1/4" gyp board to be installed on both sides of the walls. Please verify the gyp board goes inside the frame profile (add 1/2" to the new frame)

Response: The gyp board should stop at the existing door frames with corner beads on edges.

ITEM NO. 2:

Section: 01 23 00 – Alternates (not reissued)

- A. Bid Alternate 1 is described as renovation of Corridor 1HW3 (deduct). Provide a breakdown for this alternate as follows:
1. Bid Alternate 1 Part A: New floor finish, wall finishes, and built-in bench seats. The flooring is described on Sheet A-003, Key Note 11.
 2. Bid Alternate 1 Part B: New ceiling, lights, and other ceiling elements.

ITEM NO. 3:

Section: 12 24 00 – Window Shades (not reissued)

- A. Part 2 Products, 2.1 Manufacturers, notes that equal manufacturers to those indicated in drawings are acceptable, as approved by Architect.
1. Substitution form submitted by Creative Windows is approved and will be an acceptable bidder.

END OF ADDENDUM