

**REQUEST FOR PROPOSAL  
RFP# 922151X Addendum**

**CENTRAL SCHOOLS BOILER REPLACEMENT**

RFP Timeline	
RFP Issue Date:	February 6, 2026
Mandatory Walk Through:	February 11, 2026
Deadline for Respondent Questions to MSU:	February 12, 2026
<b>RFP Response Due Date:</b>	<b>February 18, 2026, 3:00 pm Eastern</b>
Estimated Contract Award	February 20, 2026

RFP Contact	
Name:	Chuck Dion
Email:	<a href="mailto:dionchar@msu.edu">dionchar@msu.edu</a>
Phone:	517-884-6170

**DESCRIPTION:** Michigan State University (the “**University**” or “**MSU**”) is soliciting proposals through this Request for Proposal (“**RFP**”) for the purpose of Providing Central Schools Boiler Replacement. The requested services are more thoroughly described under the Scope of Work Section of this RFP. Firms intending to respond to this RFP are referred to herein as a “**Respondent**” or “**Supplier.**”

## REVISED SCOPE OF WORK

### Central Schools Boiler Replacement

This Addendum is for 922151X CENTRAL SCHOOLS BOILER REPLACEMENT

Please quote the following Mechanical work for the Summer of 2026:

- Demolition of QTY (3)
- Demolition of Associated Boiler Piping
- Demolition of Associated Boiler Venting – (including the chase venting)
- Hauling old equipment off campus
- Staging New Equipment
- Supply / Install FTXL Fire Tube 399,000 BTU Condensing Boiler QTY (2)
  - CSD-1/Start Up
  - We do not want the lead /lag control option, MSUs controls will enable the boilers independently
  - No BACnet board needed (we are hard wiring the boilers)
- Supply / Install Associated Venting (Use old chase way)
- Supply / Install Associated Piping – Alter piping to primary / secondary system
- Replace Building Pumps
- Replace Expansion Tank
- Replace Air separator

Additional Line Item

- Demo Electric Water Heater
- Supply/Install Boiler Mate system for DHW

Notes: IPF oversees the electrical portion of the job, abatement and new pipe insulation