

MSU – GRRC
Grand Rapids Research
Center 400 Monroe Ave. NW
Grand Rapids, MI 49503

1st FLOOR

EQUIPMENT /	MFR.	MODEL	SERIAL / RATING	FILTERS	LOCATION
PRV Steam Station	Viola				1 st FLOOR Plumbing Room 1006
CRU-2 Steam Condensate Return Unit	B & G	52CB45-15	¾ Hp.		1 st FLOOR Plumbing Room 1006
Steam Condensate Cooling Station	Spirax / Sarco	Job 152042	C58215		1 st FLOOR Plumbing Room 1006
HHWP-9 Heating HW Emergency Circ. Pump	B & G	2BDE-1510	7 ½ Hp.		1 st FLOOR Plumbing Room 1006
HHWP-1 Heating Hot Water Pump	B & G	4GCE-1510	30 Hp.		1 st FLOOR Plumbing Room 1006
HHWP-2 Heating Hot Water Pump	B & G	4GCE-1510	50 Hp.		1 st FLOOR Plumbing Room 1006
HX-1 Steam to Water Heat Exchanger	B & G		Shell & Tube		1 st FLOOR Plumbing Room 1006
HX-2 Steam to Water Heat Exchanger	B & G		Shell & Tube		1 st FLOOR Plumbing Room 1006
HX-3 Snow Melt Heat Exchanger	B & G	BP410-30	30 Plates & Frame		1 st FLOOR Plumbing Room 1006
HX-4 Snow Melt Heat Exchanger	B & G	BP410-30	20 Plates & Frame		1 st FLOOR Plumbing Room 1006
HX-7 Domestic Hot Water Pre-heat Heat Exchanger	B & G	BP410-30	31 Plates & Frame		1 st FLOOR Plumbing Room 1006
Domestic Water Booster (2) Pumps Station	B & G TechnoForce Xylem	V2VGD6H22C1 GCK	1012737 7 ½ Hp. Each Variable Speed		1 st FLOOR Plumbing Room 1006
FCU-1005 Fan Coil Unit	Daikin			30% Pleated Filter	1 st FLOOR MDF Room 1005
FCU-1301 Fan Coil Unit	Daikin			30% Pleated Filter	1 st FLOOR MDF Room 1301

MSU – GRRC
Grand Rapids Research Center
400 Monroe Ave. NW
Grand Rapids, MI 49503

1st FLOOR

EQUIPMENT /	MFR.	MODEL	SERIAL / RATING	FILTERS	LOCATION
UH-1 HW Unit Heater	Sterling	HS-10BA			1 st FLOOR Fire Pump Room 1006A
UH-2 HW Unit Heater	Sterling	HS-10BA			1 st FLOOR Plumbing Room 1006
UH-3 HW Unit Heater					1 st FLOOR Bldg. Mgr. Room 1308A
UH-4 HW Unit Heater	Sterling	HS-10BA			1 st FLOOR Bldg. Mgr. NE Room 1308
DH-1 HW Duct Heater	Berner	IDC12-1060W			1 st FLOOR Bldg. Mgr. NE Corridor Ceiling 1308
DH-2 HW Duct Heater	Berner	IDC12-2096W			1 st FLOOR Bldg. Mgr. NE Ceiling 1308A
DH-3 Duct Heater	Berner	IDC12-2096W			1 st FLOOR Bldg. Mgr. NE Ceiling 1308A
CUH-1 HWCabinet Unit Heater	Modine	CW-06		Poly Filter	1 st FLOOR East Stairway SW2
CUH-4 HW Cabinet Unit Heater	Modine	CW-03		Poly Filter	1 st FLOOR SW Vestibule Ceiling 1VB1
EF-9 Exhaust Fan Inline	Greenheck	Backward Incline	15 Hp.		1 st FLOOR NW Electric Room 1919 Ceiling
SF-6 Exhaust Fan	Greenheck	Backward Incline	15 Hp.		1 st FLOOR NW Electric Room 1919 Ceiling
Ice Machine	Hoshizaki				1 st FLOOR Outside of Research Lab in Equip. Corridor
SMP-1 Snow Melt Pump	B & G	1 ½ A Series 90	1 ½ Hp.		1 st Floor Plumbing Room
SMP-2 Snow Melt Pump	B & G	1 ½ A Series 90	1 ½ Hp.		1 st Floor Plumbing Room

MSU – GRRC
Grand Rapids Research Center
400 Monroe Ave. NW
Grand Rapids, MI 49503

2nd FLOOR

EQUIPMENT /	MFR.	MODEL	SERIAL / RATING	FILTERS	LOCATION
Walk-in Cooler 1 – Evap. Coil					2 nd FLOOR North Side of Bldg. - Cold Room 2303
Condensing Unit Water Cooled					2 nd FLOOR North Side of Bldg. - Cold Room 2303 On Top of Cooler
Walk-in Cooler 1 – Evap. Coil					2 nd FLOOR North Side of Bldg. - Cold Room 2304
Condensing Unit Water Cooled					2 nd FLOOR North Side of Bldg. - Cold Room 2304 On Top of Cooler
Ice Machine	Hoshizaki				2 nd FLOOR Outside of Research Lab in Equip. Corridor
FCU-2003 Fan Coil Unit	Daikin			Filters	2 nd FLOOR IDF Room 2003
FCU-2004 Fan Coil Unit	Daikin			Filters	2 nd FLOOR Electrical Room 2004
					2nd FLOOR
FACB-1 Fan Assisted Chilled Beam Unit	Motivair	MCD-20-M12		2 – 1” Filters	Outside of Research Lab in Equip. Corridor
FACB-1 Fan Assisted Chilled Beam Unit	Motivair	MCD-20-M12		2 – 1” Filters	Outside of Research Lab in Equip. Corridor
FACB-1 Fan Assisted Chilled Beam Unit	Motivair	MCD-20-M12		2 – 1” Filters	Outside of Research Lab in Equip. Corridor
FACB-1 Fan Assisted Chilled Beam Unit	Motivair	MCD-20-M12		2 – 1” Filters	Outside of Research Lab in Equip. Corridor
FACB-1 Fan Assisted Chilled Beam Unit	Motivair	MCD-20-M12		2 – 1” Filters	Outside of Research Lab in Equip. Corridor

MSU – GRRC
Grand Rapids Research Center
400 Monroe Ave. NW
Grand Rapids, MI 49503

3rd FLOOR

EQUIPMENT /	MFR.	MODEL	SERIAL / RATING	FILTERS	LOCATION
Walk-in Cooler 1 – Evap. Coil					3 rd FLOOR North Side of Bldg. - Cold Room 3303
Condensing Unit Water Cooled					3 rd FLOOR North Side of Bldg. - Cold Room 3303 On Top of Cooler
Walk-in Cooler 1 – Evap. Coil					3 rd FLOOR North Side of Bldg. - Cold Room 3304
Condensing Unit Water Cooled					3 rd FLOOR North Side of Bldg. - Cold Room 3304 On Top of Cooler
Ice Machine	Hoshizaki				3 rd FLOOR Outside of Research Lab in Equip. Corridor
FCU-3003 Fan Coil Unit	Daikin			Filters	3 rd FLOOR IDF Room 3003
FCU-3004 Fan Coil Unit	Daikin			Filters	3 rd FLOOR Electrical Room 3004
					3rd FLOOR
FACB-1 Fan Assisted Chilled Beam Unit	Motivair	MCD-20-M12		2 – 1” Filters	Outside of Research Lab in Equip. Corridor
FACB-1 Fan Assisted Chilled Beam Unit	Motivair	MCD-20-M12		2 – 1” Filters	Outside of Research Lab in Equip. Corridor
FACB-1 Fan Assisted Chilled Beam Unit	Motivair	MCD-20-M12		2 – 1” Filters	Outside of Research Lab in Equip. Corridor
FACB-1 Fan Assisted Chilled Beam Unit	Motivair	MCD-20-M12		2 – 1” Filters	Outside of Research Lab in Equip. Corridor
FACB-1 Fan Assisted Chilled Beam Unit	Motivair	MCD-20-M12		2 – 1” Filters	Outside of Research Lab in Equip. Corridor

MSU – GRRC
Grand Rapids Research Center
400 Monroe Ave. NW
Grand Rapids, MI 49503

4th FLOOR

EQUIPMENT /	MFR.	MODEL	SERIAL / RATING	FILTERS	LOCATION
Walk-in Cooler 1 – Evap. Coil					4th FLOOR North Side of Bldg. - Cold Room 4303
Condensing Unit Water Cooled					4th FLOOR North Side of Bldg. - Cold Room 4303 On Top of Cooler
Walk-in Cooler 1 – Evap. Coil					4th FLOOR North Side of Bldg. - Cold Room 4304
Condensing Unit Water Cooled					4th FLOOR North Side of Bldg. - Cold Room 4304 On Top of Cooler
Ice Machine	Hoshizaki				4th FLOOR Outside of Research Lab in Equip. Corridor
FCU-4003 Fan Coil Unit	Daikin			Filters	4th FLOOR IDF Room 4003
FCU-4004 Fan Coil Unit	Daikin			Filters	4th FLOOR Electrical Room 4004
					4th FLOOR
FACB-1 Fan Assisted Chilled Beam Unit	Motivair	MCD-20-M12		2 – 1” Filters	Outside of Research Lab in Equip. Corridor
FACB-1 Fan Assisted Chilled Beam Unit	Motivair	MCD-20-M12		2 – 1” Filters	Outside of Research Lab in Equip. Corridor
FACB-1 Fan Assisted Chilled Beam Unit	Motivair	MCD-20-M12		2 – 1” Filters	Outside of Research Lab in Equip. Corridor
FACB-1 Fan Assisted Chilled Beam Unit	Motivair	MCD-20-M12		2 – 1” Filters	Outside of Research Lab in Equip. Corridor
FACB-1 Fan Assisted Chilled Beam Unit	Motivair	MCD-20-M12		2 – 1” Filters	Outside of Research Lab in Equip. Corridor

5th FLOOR

[illegible]

MSU – GRRC
Grand Rapids Research Center
400 Monroe Ave. NW
Grand Rapids, MI 49503

6th FLOOR

EQUIPMENT /	MFR.	MODEL	SERIAL / RATING	FILTERS	LOCATION
FCU-6107 Fan Coil Unit	Daikin			Filters	6th FLOOR IDF Room 6107
FCU-6104 Fan Coil Unit	Daikin			Filters	6th FLOOR Electrical Room 6104
FCU-6106 Fan Coil Unit	Daikin			Filters	6th FLOOR South Middle Storage by S. Elevator Room 6106
AHU-1 Air Handling Unit w/ HW & CW Coils, Economizer, Supply & Return Fans, VFD	York	XTI-114X132- QQL046A	ALCMXT0267 4 – S/A Fans 15 Hp. ea. 2 – R/A Fans 15 Hp. ea.	20 – 20x24x2 5 – 24x24x2 30% Pleated Merv 8 Info Only 20 – 20x24x22 5 – 24x24x22 Bag Filters Merv 14	6th FLOOR Penthouse Serves: 1 st and 5 th Floor Office Areas
H-1 Steam Humidifier	Dri Steem	M551			6th FLOOR Penthouse Located on AHU-1
Return Fan	Greenheck	AX-90-275	20 Hp.		6th FLOOR Penthouse For AHU-1
AHU-2 Air Handling Unit w/ HW & CW Coils, Economizer, Supply, VFD	York	XTI-120X138- QALLS046A	ALCMXT0268 4 – S/A Fans 15 Hp. ea. 2 – R/A Fans 15 Hp. ea.	20 – 20x24x2 5 – 24x24x2 30% Pleated Merv 8 Info Only 20 – 20x24x22 5 – 24x24x22 Bag Filters Merv 14	6th FLOOR Penthouse Serves: Admin. Office Shell Areas – Floors 2,3,4 & Atrium
H-2 Steam Humidifier	Dri Steem	M551			6th FLOOR Penthouse Located on AHU-2
Return Fan	Greenheck	AX-90-275	20 Hp.		6th FLOOR Penthouse For AHU-2

MSU – GRRC
Grand Rapids Research Center
400 Monroe Ave. NW
Grand Rapids, MI 49503

PENTHOUSE

EQUIPMENT /	MFR.	MODEL	SERIAL / RATING	FILTERS	LOCATION
FCU-7004 Fan Coil Unit	Daikin			Filters	Penthouse Elevator Control Room 7004
FCU-7005 Fan Coil Unit	Daikin			Filters	Penthouse By Chilled Water Circ. Pumps
FCU-7006 Fan Coil Unit	Daikin			Filters	Penthouse By AHU-3
AHU-3A Air Handling Unit w/ HW & CW Coils, 100% OA, Fan Wall Supply Fans, VFD	Air Flow Intertek Venmarces	Energy Pack W-2-64i-WX- HW-CW-X-P	00807986- C07660 8 – S/A Fans 15 Hp. ea.	20 – 20x24x2 5 – 24x24x2 30% Pleated Merv 8 <u>Info Only</u> 20 – 20x24x?? 5 – 24x24x?? Box Filters Merv 14	Penthouse Serves: Floors 2,3,4 Lab Areas and 5 th Floor Research Shell
H-3 Steam Humidifier	Dri Steem				Penthouse Located on AHU-3A
ERW-1 Total Energy Recovery Wheel	Innergytech	13-MS3A-120			Penthouse AHU-3A
AHU-3B Air Handling Unit w/ HW & CW Coils, Economizer, Supply & Return Fans, VFD	Air Flow Intertek Venmarces	Energy Pack W-2-64i-WX- HW-CW-X-P	00807986- C07660 8 – S/A Fans 15 Hp. ea.	20 – 20x24x2 5 – 24x24x2 30% Pleated Merv 8 <u>Info Only</u> 20 – 20x24x?? 5 – 24x24x?? Box Filters Merv 14	Penthouse Serves: Floors 2,3,4 Lab Areas and 5 th Floor Research Shell
H-3 Steam Humidifier	Dri Steem				Penthouse Located on AHU-3B
ERW-1 Total Energy Recovery Wheel	Innergytech	13-MS3A-120			Penthouse AHU-3B

MSU – GRRC
Grand Rapids Research Center
400 Monroe Ave. NW
Grand Rapids, MI 49503

PENTHOUSE

EQUIPMENT /	MFR.	MODEL	SERIAL / RATING	FILTERS	LOCATION
AHU-4A Air Handling Unit w/ HW & CW Coils, 100% OA, Fan Wall Supply Fans, VFD	Air Flow Intertek Venmarces	Energy Pack W-2-631-VVX- HW-CW-X-P	00808179- C07668 8 – S/A Fans 15 Hp. ea.	20 – 20x24x2 5 – 24x24x2 30% Pleated Merv 8 <u>Info Only</u> 20 – 20x24x?? 5 – 24x24x?? Box Filters Merv 14	Penthouse Serves: Floors 2,3,4 Lab Areas and 5 th Floor Research Shell
H-3 Steam Humidifier	Dri Steem				Penthouse Located on AHU-4A
ERW-1 Total Energy Recovery Wheel	Innerytech	13-MS3A-120			Penthouse AHU-4A
AHU-4B Air Handling Unit w/ HW & CW Coils, Economizer, Supply & Return Fans, VFD	Air Flow Intertek Venmarces	Energy Pack W-2-631-VVX- HW-CW-X-P	00808179- C07668 8 – S/A Fans 15 Hp. ea.	20 – 20x24x2 5 – 24x24x2 30% Pleated Merv 8 <u>Info Only</u> 20 – 20x24x?? 5 – 24x24x?? Box Filters Merv 14	Penthouse Serves: Floors 2,3,4 Lab Areas and 5 th Floor Research Shell
H-3 Steam Humidifier	Dri Steem				Penthouse Located on AHU-4B
ERW-1 Total Energy Recovery Wheel	Innerytech	13-MS3A-120			Penthouse AHU-4B
#1 Domestic Hot Water Heater Steam to Water	Cemline		68235		Penthouse By AHU-4B
#2 Domestic Hot Water Heater Steam to Water	Cemline		68234		Penthouse By AHU-4B

MSU – GRRC
Grand Rapids Research Center
400 Monroe Ave. NW
Grand Rapids, MI 49503

PENTHOUSE

EQUIPMENT /	MFR.	MODEL	SERIAL / RATING	FILTERS	LOCATION
AHU-5A Air Handling Unit w/ HW & CW Coils, 100% OA, Fan Wall Supply Fans, VFD	Air Flow Intertek Venmarces	Energy Pack P-2-19i-WX- HW-CW-X-P	00808110- C07678 8 – S/A Fans 10 Hp. ea.	20 – 20x24x2 5 – 24x24x2 30% Pleated Merv 8 <u>Info Only</u> 20 – 20x24x?? 5 – 24x24x?? Box Filters Merv 14	Penthouse Serves: 6 th Floor Vivarium
H-3 Steam Humidifier	Dri Steem				Penthouse Located on AHU-5A
ERHX-1 Energy Recovery Plate Heat Exchanger					Penthouse AHU-5A
AHU-5B Air Handling Unit w/ HW & CW Coils, Economizer, Supply & Return Fans, VFD	Air Flow Intertek Venmarces	Energy Pack P-2-19i-WX- HW-CW-X-P	00808110- C07678 8 – S/A Fans 10 Hp. ea.	20 – 20x24x2 5 – 24x24x2 30% Pleated Merv 8 <u>Info Only</u> 20 – 20x24x?? 5 – 24x24x?? Box Filters Merv 14	Penthouse Serves: 6 th Floor Vivarium
H-3 Steam Humidifier	Dri Steem				Penthouse Located on AHU-5B
ERW-1 Total Energy Recovery Wheel	Innergytech	13-MS3A-120			Penthouse AHU-5B

MSU – GRRC
Grand Rapids Research Center
400 Monroe Ave. NW
Grand Rapids, MI 49503

PENTHOUSE

EQUIPMENT /	MFR.	MODEL	SERIAL / RATING	FILTERS	LOCATION
CH-1 Chiller	York	YKECERQ6- EMG	SLCM-376590	Replacement Oil Filter Element # 026-32831- 000	Penthouse SW Corner
Centrifugal Compressor	-----	Model # YDHF- 491VDD	York K Oil	Compressor Oil Filters (2) Filter Assbly. 026-47427- 000	Room PH7001
VFD – Requires 1 ½ gal. York Glycol			450 Tons		
Gear	-----	WV	1,028 lbs. 134a Refrig		
CH-2 Chiller	York	YKECERQ6- EMG	SLCM-376750	Replacement Oil Filter Element # 026-32831- 000	Penthouse SW Corner
Centrifugal Compressor	-----	Model # YDHF- 491VDD	York K Oil	Compressor Oil Filters (2) Filter Assbly. 026-47427- 000	Room PH7001
VFD – Requires 1 ½ gal. York Glycol			450 Tons		
Gear	-----	WV	1,028 lbs. 134a Refrig.		
Refrigerant Leak Detection System	Haloguard IR				Penthouse SW Corner Room PH7001
HX-5 Chiller Water Heat Exchanger	Bell & Gossett	P62	30% Propylene Glycol		Penthouse SW Corner Room PH7001
HX-6 Chiller Water Heat Exchanger	Bell & Gossett	P64	30% Propylene Glycol		Penthouse SW Corner Room PH7001

PENTHOUSE

[illegible]

MSU – GRRC
Grand Rapids Research Center
400 Monroe Ave. NW
Grand Rapids, MI 49503

FAN SCHEDULE

EQUIPMENT /	MFR.	MODEL	SERIAL / RATING	FILTERS	LOCATION
EF-1 Exhaust Fan	Strobic	TS1L150B18	15 Hp.		Penthouse Roof For Fume Hoods
EF-2 Exhaust Fan	Strobic	TS1L150B18	15 Hp.		Penthouse Roof For Fume Hoods
EF-3 Exhaust Fan	Strobic	TS1L150B18	15 Hp.		Penthouse Roof For Fume Hoods
EF-4 Exhaust Fan	Strobic	TS1L150B12	50 Hp.		Penthouse Roof For Fume Hoods
EF-5 Exhaust Fan	Strobic	TS1L150B12	50 Hp.		Penthouse Roof For Fume Hoods
EF-6 Exhaust Fan	Strobic	TS1L150B12	50 Hp.		Penthouse Roof For Fume Hoods
EF-7 Exhaust Fan	Strobic	TS1L150B12	50 Hp.		Penthouse Roof For Fume Hoods
EF-8A Exhaust Fan	Strobic	TS1L150B12	40 Hp.		Penthouse Roof For Fume Hoods
EF-8B Exhaust Fan	Strobic	TS1L150B12	40 Hp.		Penthouse Roof For Fume Hoods
EF-9 Exhaust Fan	Greenheck		15 Hp.		1 st Floor NW Electrical Room
EF-10 Exhaust Fan	Strobic	TS1L150B18	15 Hp.		Roof For Fume Hoods
EF-11 Inline Exhaust Fan Upblast	Greenheck	USGF-14HP7	1 Hp.		Penthouse Yard Roof
EF-12 Exhaust Fan	Greenheck	USF-212-10- B1-30	3 Hp.		Penthouse Chiller Room
PF-1 Exhaust Fan	Greenheck	BSQ	10 Hp.		Roof For Stairway SW
PF-2 Exhaust Fan	Greenheck	BSQ	10 Hp.		Roof For Stairway SW
SEF-1 Smoke Exhaust Fan	Greenheck	AX-113-275	15 Hp.		Penthouse Roof For Atrium
SEF-2 Smoke Exhaust Fan	Greenheck	AX-113-275	15 Hp.		Penthouse Roof For Atrium
SEF-3 Smoke Exhaust Fan	Greenheck	AX-113-275	15 Hp.		Penthouse Roof For Atrium
SEF-4 Smoke Exhaust Fan	Greenheck	AX-113-275	15 Hp.		Penthouse Roof For Atrium
SF-6 Supply Exhaust Fan	Greenheck		15 Hp.		1 st Floor NW Electrical Room
SF-7 Supply Exhaust Fan	Greenheck		1 Hp.		1 st Floor NW Plumbing Room
SF-8 Exhaust Fan	Greenheck	RSFP-100-20	2 Hp.		Penthouse Chiller Room
TEF-1 Toilet Exhaust Fan	Greenheck	GB-180	2 Hp.		Penthouse Yard Roof

MSU – GRRC
Grand Rapids Research Center
400 Monroe Ave. NW
Grand Rapids, MI 49503

CIRCULATION PUMP SCHEDULE

PENTHOUSE

EQUIPMENT /	MFR.	MODEL	SERIAL / RATING	FILTERS	LOCATION
CHWP-1 Chiller Water Pump	B & G	VSC- 5X6X10.5A	50 Hp.		Penthouse
CHWP-2 Chiller Water Pump	B & G	VSC- 5X6X10.5A	50 Hp.		Penthouse
CHWP-5 Chiller Water Pump	B & G	3BD	7 ½ Hp.		Penthouse Emergency
CWP-1 Condenser Water Pump	B & G	VSH- 8X10X10.5B	50 Hp.		Penthouse Roof
CWP-2 Condenser Water Pump	B & G	VSC- 5X6X10.5A	50 Hp.		Penthouse
CWP-3 Condenser Water Pump	B & G	3BD	10 Hp.		Penthouse
HHWP-3 Heating Hot Water Pump	B & G	4GCE-1510	50 Hp.		Penthouse AHU-1
HHWP-4 Heating Hot Water Pump	B & G	2.5x2.5x7	1 ½ Hp.		Penthouse AHU-2
HHWP-5A Heating Hot Water Pump	B & G	4x4x9.5	2 Hp.		Penthouse AHU-3
HHWP-5B Heating Hot Water Pump	B & G	4x4x9.5	2 Hp.		Penthouse AHU-3
HHWP-6A Heating Hot Water Pump	B & G	4x4x9.5	2 Hp.		Penthouse AHU-4
HHWP-6B Heating Hot Water Pump	B & G	4x4x9.5	2 Hp.		Penthouse AHU-4
HHWP-7A Heating Hot Water Pump	B & G	3x3x9.5B	2 Hp.		Penthouse AHU-5A

CIRCULATION PUMP SCHEDULE

[illegible]

MSU – GRRC
Grand Rapids Research Center
400 Monroe Ave. NW
Grand Rapids, MI 49503

HW CABINET & UNIT HEATER SCHEDULE

EQUIPMENT /	MFR.	MODEL	SERIAL / RATING	FILTERS	LOCATION
CUH-1 Cabinet Unit Heater	Modine	CW-06	.05 Hp.	Filters	1 st Floor SW2
CUH-2 Cabinet Unit Heater	Modine	CW-03	.03 Hp.	Filters	1 st Floor SW3
CUH-4 Cabinet Unit Heater	Modine	CW-06	.03 Hp.	Filters	1 st Floor 1VB1
DH-1 Duct Heater	Berner	IDC12-1060W	.05 Hp.		1 st Floor Room 1308
DH-2 Duct Heater	Berner	IDC12-2060W	.05 Hp.		1 st Floor Room 1308
DH-3 Duct Heater	Berner	IDC12-2060W	.05 Hp.		1 st Floor Room 1308
UH-1 Unit Heater	Sterling	HS-108A	.02 Hp.		1 st Floor 1006A
UH-2 Unit Heater	Sterling	HS-108A	.02 Hp.		1 st Floor 1006
UH-4 Unit Heater	Sterling	HS-108A	.02 Hp.		1 st Floor 1308
UH-6 Unit Heater	Sterling	HS-125A	.03 Hp.		7 th Floor PH7000
UH-7 Unit Heater	Sterling	HS-125A	.03 Hp.		7 th Floor PH7000
UH-8 Unit Heater	Sterling	HS-125A	.03 Hp.		7 th Floor PH7000
UH-9 Unit Heater	Sterling	HS-125A	.03 Hp.		7 th Floor PH7000
UH-10 Unit Heater	Sterling	HS-125A	.03 Hp.		7 th Floor PH7000
UH-11 Unit Heater	Sterling	HS-125A	.03 Hp.		7 th Floor PH7000

HW CABINET & UNIT HEATER SCHEDULE

[illegible]

[illegible]